

HIMA K9203

19-Inch Subrack Fan Module

Verified identification and technical data

Manufacturer	HIMA Paul Hildebrandt GmbH
Model	K9203
Product family	H41 / H51
Product type	19-Inch Subrack Fan Module
Primary application	Subrack ventilation
Module type	Fan module
Mechanical scope	19-inch subrack
System scope	H41, H51, H41q and H51q automation systems
Official designation	K9203
Compatibility	Verify the exact model, revision, wiring and certified application before replacement.

Manufacturer source used

HIMA FM Approval Report

<https://www.hima.com/dodownload/60271>

Only information within the cited manufacturer-source scope is reproduced. No unverified rating, dimension, interchangeability or lifecycle claim is added.

SALES/PLCAUT

HIMA K9203

Replacement and installation checks

- Match the complete model, suffix and hardware revision against the installed unit and approved bill of materials.
- Confirm rack, slot, connector, wiring, channel assignment, sensor or system interface before removal.
- Back up applicable project data and record the original installation before disturbing connections.
- Use qualified personnel and the current manufacturer installation, commissioning and safety-validation procedure.
- Do not infer compatibility from similar appearance or a related model number.

Questions commonly raised by engineers

How should K9203 identity be checked before ordering?

Match the complete model, suffix, hardware revision and visible nameplate details. Do not select K9203 from appearance alone.

What compatibility information is needed for K9203?

Confirm the installed H41 / H51, rack or housing, slot, mating connector, wiring and project bill of materials.

What should be reviewed before installing K9203?

Use qualified personnel, isolate the affected equipment under the site procedure, preserve the original configuration and follow current manufacturer instructions.

Which application context applies to K9203?

The official-source scope identifies it in the context of 19-Inch Subrack Fan Module. Final suitability remains application- and revision-specific.

What must be tested after replacing K9203?

Perform the approved diagnostics, channel or communication checks and any required safety-function validation before returning the equipment to service.

What information should accompany a K9203 quotation request?

Provide quantity, destination, required condition and clear front, side and nameplate photographs, plus the surrounding rack or sensor context.

Request exact-model verification or a quotation
sales8@amikon.cn | +86 18030235313
www.salesplcauto.com

Independent reference prepared by SalesPLCAuto from the cited manufacturer source. It is not a manufacturer-issued datasheet or a substitute for the current project documentation.